


भारत सरकार कार्यपालक अभियन्ता- भुवनेश्वर-२ का कार्यालय केन्द्रीय लोक निर्माण विभाग निर्माण भवन, भुवनेश्वर – 751020 टेलिफोन सं०.0674-2352941 फैक्स सं०. 0674-2352931	 CPWD	GOVERNMENT OF INDIA OFFICE OF THE EXECUTIVE ENGINEER- Bhubaneswar -II CENTRAL PUBLIC WORKS DEPARTMENT NIRMAN BHAWAN Plot No.188/623-624, Pokhariput, Bhubaneswar-751020 Telephone No.0674-2352941 Fax No.0674-2352931 Email.eebcd2bhubaneswar@gmail.com
---	---	--

संख्या: 23(100)/EE/Bhubaneswar-II/CPWD/2024/141

दिनांक: 21/03/2024.

सेवा में,

The Principal,
PM Shri Kendriya Vidyalaya No.4,
At- Niladri Vihar, PO- Shailashree Vihar,
Bhubaneswar – 751021.
E-mail: kv4bbsr@gmail.com

विषय: Regarding Structural Building Safety Certificate for PM SHRI Kendriya Vidyalaya No-4, Bhubaneswar, At-Niladri Vihar, PO-Shailashree Vihar, Bhubaneswar.

Ref No 1. Your letter No:150112(CBSE)/1148/KV4BBSR/2024/781 dated 12.03.2024.
2. Assistant Engineer-C-5 letter No.54(KV)/EE-BBSR-II/2024/22 dated 18/03/2024.

महोदय,

Please refer to your letter under reference vide which a Structural Building Safety Certificate in respect of K.V. No.4, Bhubaneswar has been sought by your good office.

It is to inform you that the building K.V. No.4, Bhubaneswar, was not constructed by CPWD. As per your request, the concerned Assistant Engineer-C-5, CPWD, Bhubaneswar visited physically on dated 15/03/2024 and conducted a visual inspection, evaluating the building's safety. Accordingly, based on visual inspection, the Assistant Engineer has noted that the building necessitates minor repairs and routine maintenance works. Further, it is to inform you that presently, no visible cracks have been detected in structural members and on the basis of visual observation, it is certified that the K.V. No.4, Shailashree Vihar, Bhubaneswar is structurally safe.

This is for your kind information & necessary action please.

भवदीय/ Yours faithfully,



(इं. आशीष गुप्ता)

कार्यपालक अभियन्ता- भुवनेश्वर-II
के.लो.नि.वि, भुवनेश्वर-751020**प्रतिलिपि प्रेषित/Copy to:-**

1. The Assistant Engineer (C-5), CPWD, Bhubaneswar.

कार्यपालक अभियन्ता- भुवनेश्वर-II